



Akuna Bay: Water Treatment Monitoring Results

Monitoring Point 1: Discharge from Sewage Treatment Plant

Pollutants Monitored:	pH	Total Suspended Solids	Biochemical Oxygen Demand
License limit	6.5 - 8.5	30	20
Units of Measurement	Range of pH	milligrams per litre	milligrams per litre

Results

9-Jan-17	7.44	8	20
16-Sep-16	7.21	11	30
20-Jul-16	7.12	4	9
21-Jun-16	7.04	11	3
16 May 2016	7.80	5	11
10 March 2016	7.04	2	51
16 January 2016	7.03	5	61
30 November 2015	7.00	6	76
27 October 2015	7.40	3	16
26 August 2015	7.55	42	85
23 July 2015	7.60	32	45
25 June 2015	7.00	7	17
11 May 2015	7.60	8	8
31 March 2015	7.70	18	20
15 January 2015	7.04	14	17
23 October 2014	7.07	3	26
28 August 2014	7.00	9	16
9 July 2014	7.03	28	18
23 May 2014	7.50	5	6
7 April 2014	7.00	11	66
6 February 2014	7.07	8	11
23 December 2013	7.03	5	6
5 November 2013	7.08	9	16
24 August 2013	7.19	16	4
31 July 2013	7.05	37	63
22 May 2013	7.04	7	95
22 February 2013	7.60	4	15
20 February 2013	7.60	1	80
20 February 2013	7.60	7	24
12 February 2013	7.60	4	15
11 February 2013	7.70	2	25
5 February 2013	8.20	7	24
14 January 2013	7.30	10	69
1 February 2012	6.50	11	15

This document contains information and data sourced from third parties. While reasonable care has been taken in relation to the preparation of this document, any person using or relying on the information and data (whether for commercial purposes or otherwise) does so at their own risk. Ardent Leisure (including its affiliates, employees, agents, contractors and representatives) makes no representation or warranties as to the accuracy or completeness of such information or data, and to the extent permitted by law excludes all liability for any loss or damage (whether caused by negligence or otherwise) resulting from reliance thereon.